



कार्यालय नगर स्वास्थ्य अधिकारी  
नगर निगम, मेरठ।

पत्रांक : 153/ स्वा०वि०-न०नि०मे०/ 2025

दिनांक: 12.07.2025

### प्रमाण पत्र

सेवा में,

प्रबन्धक/प्रधानाचार्य,  
एमआईईटी पब्लिक स्कूल  
पीएस-1, पॉकेट-क्यू, पल्लवपुरम, फेस-11,  
मेरठ-250110

आपके प्रार्थना पत्र दिनांक 11.07.2025 जिसके अन्तर्गत आपके द्वारा अपनी संस्था सोसाइटी फॉर एडवांस साइन्टिफिक एजुकेशन, मेरठ में संचालित स्कूल एमआईईटी पब्लिक स्कूल, पीएस-1, पॉकेट-क्यू, पल्लवपुरम, फेस-11, मेरठ-250110 के लिये प्रमाण पत्र निर्गत किये जाने हेतु अनुरोध किया गया है।

उक्त के सम्बन्ध में विद्यालय का स्थलीय निरीक्षण किया गया निरीक्षण के दौरान पाया गया कि:-

1. स्कूल में सभी कक्ष रूम, प्रयोगशाला एवं लाइब्रेरी स्वच्छ एवं हवादार है।
2. स्कूल में पीने के पानी की उचित व्यवस्था पाई गई एवं स्कूल में आर०ओ० प्लान्ट स्थापित एवं संचालित है।
3. स्कूल में यूरिनल व शौचालय साफ-सुथरे एवं पर्याप्त व्यवस्था में पाये गये तथा इनकी सफाई हेतु कर्मचारी उपास्थित पाये गये।
4. स्कूल प्रांगण एवं आस-पास में सफाई व्यवस्था संतोषजनक पायी गई।

अतः आपके स्कूल एमआईईटी पब्लिक स्कूल, पीएस-1, पॉकेट-क्यू, पल्लवपुरम, फेस-11, मेरठ-250110 को प्रमाण-पत्र इस शर्त के अनुसार निर्गत किया जाता है कि आप स्कूल में उक्त सभी व्यवस्थाओं को भविष्य में भी बनाये रखेंगे। यह प्रमाण पत्र शैक्षिक सत्र 2025-26 से आगामी 01 वर्षों के लिये मान्य होगा परन्तु नियमों का अनुपालन न करने की स्थिति में प्रमाण पत्र निरस्त कर दिया जायेगा। स्वास्थ्य एवं जलवायु की दृष्टि से कोई आपत्ति नहीं है।

MIET PUBLIC SCHOOL

PRINCIPAL

नगर स्वास्थ्य अधिकारी  
नगर निगम, मेरठ।

For MIET PUBLIC SCHOOL

Chairman



# ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory



(AN ISO 45001:2018 Certified Laboratory)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

E-mail : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461

TC-15390



## TEST REPORT

TEST REPORT NO.: ETS/1367/10/2025

ULRNO.TC153902500001367F

DATE OF REPORT: 15.10.2025

### WATER SAMPLE ANALYSIS REPORT

Name And Address of Customer : MIET PUBLIC SCHOOL  
POCKET Q, PALLAVPURAM PHASE-2  
MEERUT-250110

Date of Sample Received : 10.10.2025  
Analysis Start Date : 11.10.2025  
Analysis End Date : 15.10.2025  
Sample ID No : 1367  
Sampling Done By : BY CUSTOMER  
Sampling Description : DRINKING WATER  
Sampling Location : FROM R.O.  
Sampling Method : IS 3025 (Part-1)  
Sample Quantity : 2.0+0.5 Ltr  
Packing Condition : SEALED  
Packed In : P.V.C. AND GLASS BOTTLE

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012)		Test Method
				Desirable	Permissible	
<b>PHYSICAL &amp; CHEMICAL PARAMETERS;</b>						
1	pH	...	7.15	6.5 - 8.5	No Relaxation	APHA 4500-H+
2	Turbidity	NTU	<1.0	1	5	APHA 2130-B
3	Total Dissolved Solids,(TDS)	mg/L	117.3	500	2000	APHA 2540-C
4	Conductivity	µs/cm	175.8	No Relaxation	No Relaxation	APHA 2510-B
5	Free Chlorine (Residual)	mg/L	<0.02	0.2	1	APHA 4500:(Cl)-B
6	Fluoride,(F)	mg/L	<0.01	1	1.5	APHA 4500:(F-) -D
7	Total Alkalinity,(CaCO <sub>3</sub> )	mg/L	37.7	200	600	APHA 2320-B
8	Total Hardness,(CaCO <sub>3</sub> )	mg/L	50.9	200	600	APHA 2340-C
9	Calcium,(Ca)	mg/L	9.4	75	200	APHA 3500:(Ca)-B
10	Chloride,(Cl)	mg/L	8.0	250	1000	APHA 4500:(Cl-) -B
11	Magnesium,(Mg)	mg/L	6.5	30	100	APHA 3500:(Mg)-B
12	Nitrate,(NO <sub>3</sub> )	mg/L	<0.1	45	No Relaxation	APHA 4500:(NO <sub>3</sub> -)-B
13	Sulphate,(SO <sub>4</sub> )	mg/L	9.6	200	400	APHA 4500:(SO <sub>4</sub> )-E
<b>HEAVY METALS;-</b>						
14	Iron,(Fe)	mg/L	<0.05	1.0	No Relaxation	APHA-3120B

\*\*\*\*\* End of Test Report\*\*\*\*\*

For Enviro Tech Services Pvt. Ltd.

CHECKED BY  
RAMIZA BANO


AUTHORIZED SIGNATORY

Note :- Format No. ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

1. Test reports without ETS-LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. This sample shall be destroyed after 15 days. Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.

For MIET PUBLIC SCHOOL

Chairman



# ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory



ISO 45001

(AN ISO 45001:2018 Certified Laboratory)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

E-mail : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461

ETS-LAB



## TEST REPORT

TEST REPORT NO.: ETS/1367/10/2025

DATE OF REPORT: 15.10.2025

## WATER SAMPLE ANALYSIS REPORT

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012 )	Test Method
<b>MICROBIOLOGICAL PARAMETER;</b>					
15	Escherichia coli	Per 100mL	Absent	Shall Not Be Detectable	IS15185

\*\*\*\*\*End of Test Report\*\*\*\*\*

CHECKED BY  
JYOTI



No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

AUTHORIZED SIGNATORY



MIET PUBLIC SCHOOL

*[Signature]*  
PRINCIPAL

For MIET PUBLIC SCHOOL

*[Signature]*  
Chairman

Note :-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. This sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.

कार्यालय सहायक अभियन्ता (द्वितीय), मेरठ खण्ड गंगा नहर, मेरठ।

प्रमाण पत्र

पत्रांक: 89/सहायक अभियन्ता-II/

दिनांक: 23.02.2026

1. विद्यालय का नाम एवं पता: एमआईईटी पब्लिक स्कूल  
पीएस-1, पॉकेट-क्यू, पल्लवपुरम्, फेस-1।  
मेरठ-250110 (उत्तर प्रदेश)
2. विकास खण्ड: मेरठ।
3. पहुँच मार्ग: है।
4. सेट बैक: उपलब्ध है।

उक्त विद्यालय में भवन का निर्माण कार्य बेसमेन्ट+जी+2 मंजिल पूर्ण है। विद्यालय में निर्मित भवन में शिक्षण कक्ष, प्रयोगशालायें, लैट्रीन, बाथरूम, सैनीटेशन व्यवस्था, पीने के आर०ओ० पानी की व्यवस्था एवं जीने का निर्माण मानकों के अनुसार किया गया है एवं पूर्ण है। भवन का निर्माण नेशनल बिल्डिंग कोड-2005 के भाग-4 संशोधित नियम- 2016 के अनुसार सुरक्षित एवं मजबूत है। यह प्रमाण पत्र उक्त विद्यालय के पत्र दिनांक 18.02.2026 के क्रम में सी०बी०एस०ई० बोर्ड के निर्धारित प्रारूप Annexure-D के साथ निर्गत किया गया है।

Rajesh  
23/2/26  
ASSISTANT ENGINEER-II  
MEERUT DIVISION GANGA CANAL  
MEERUT

MIET PUBLIC SCHOOL  
Principal  
PRINCIPAL

For MIET PUBLIC SCHOOL  
Chairman

# Annexure D

## BUILDING SAFETY CERTIFICATE

No. 89/सदरअभिनो-II

Dated: 23.02.2026

It is certified that the existing building MIET Public School at PS-1, Pocket-Q, Pallavpuram, Phase-II, Meerut-250110 (U.P.) is having block(s)/Floor(s) as per details below:

Detail of Block(s) in school	Block (1)	Block (2)	Block (3)	Block (4)	Block (5)	Block (6)
No. of Floor(s) in the Block	Basement-1 +G+2	-	-	-	-	-

The building is owned/occupied by MIET Public School (A Unit of Society for Advance Scientific Education) have complied with the Building safety requirements in accordance with National Building Code-2005 Part-4 as amended -2016 Rules, and verified by the officers concerned of Assistant Engineer-II, Meerut Division Ganga Canal, Meerut on 23.02.2026 in the presence of Sanjay Rastogi, Head Commercial & Finance, MIET Public School, PS-1, Pocket-Q, Pallavpuram, Phase-II, Meerut-250110 (U.P.) and that the building/ premises is fit for occupancy for running school with effect from 23.02.2026 for a period of 30 years in accordance with rule and subject to compliance of the specific conditions as appended.

1. All NBC Conditions are follow by the Institution.
2. In the period of this certificate all NBC Safety points are follow by the Institution.
3. This period if any problem due to NBC , the department are not responsible.
4. This period if any problem due to NBC, the Institution are responsible all situation.

Issued on 23.02.2026 at Meerut by Assistant Engineer-II, Meerut Division Ganga Canal, Meerut.

\* Strike out whichever is not applicable. In case of block is more than six use separate sheet for detail.

*Rajesh*  
23/2/26  
ASSISTANT ENGINEER-II  
MEERUT DIVISION GANGA CANAL  
MEERUT

Signature with Seal : \_\_\_\_\_

Name : RAJESH BABOO

Designation : Assistant Engineer

Name & Address of Department/ Office: Office of the  
Executive Engineer, Meerut  
Division Ganga, Canal  
Meerut

Note: Building Safety Certificate as per the Annexure-D of the SARAS Manual is to be issued by an officer not below the rank of an Assistant Engineer of the Government works department.

MIET PUBLIC SCHOOL

PRINCIPAL

For MIET PUBLIC SCHOOL

Chairman