

## Annexure- C

### PROFORMA FOR SAFE DRINKING WATER AND SANITARY CONDITION CERTIFICATE

No.143/ स्वा.वि. - न० नि० मे० /2026

Dated: 13-03-2026

It is certified that an inspection team headed by SH. NEERAJ KUMAR, SANITARY <sup>INSPECTOR,</sup> (name of Officers with designation) from NAGAR NIGAM, MEERUT PHED Inspected the MIET PUBLIC SCHOOL, PS-I, POCKET B, PALLAY PURAM, PHASE-II <sup>MEERUT</sup> (Name & Address of the School) on 12-03-2026 (date of inspection) and on the basis of Water Test Report (Attached) bearing no. ETS/1367/10/2025 dated 15-10-2025 of ENVIRO TECH SERVICES PTE. LTD., GHAZIABAD (U.P.) <sup>201001</sup> (PHED Lab) certified that the MIET PUBLIC SCHOOL (Name of school) has safe drinking water facilities for the students and members of staff of the institution. School is also maintains the hygienic sanitation condition in the school building & the campus as per norms prescribed by the Central / State/ U.T. Govt.

This certificate is valid till 12-03-2028

Signature with Seal:  नगर स्वास्थ्य अधिकारी  
नगर निगम, मेरठ।

Name Dr. Amar Singh

Designation NSA

Name & Address of the Office/ Department:.....

कार्यालय नगर स्वास्थ्य अधिकारी  
नगर निगम, मेरठ।

To


CHAIRMAN/MANGER,  
MIET PUBLIC SCHOOL,

PS-I, POCKET B, PALLAY PURAM PHASE-II, MEERUT - 250110.

(Name and Address of the Institution)


Note : The certificate is be issued by authorized officer/ PHED Lab/ local bodies

For MIET PUBLIC SCHOOL

  
Principal

For MIET PUBLIC SCHOOL

  
Manager



# ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory



(AN ISO 45001:2018 Certified Laboratory)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

E-mail : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461

TC-15390



## TEST REPORT

TEST REPORT NO.: ETS/1367/10/2025

ULRNO.TC153902500001367F

DATE OF REPORT: 15.10.2025

### WATER SAMPLE ANALYSIS REPORT

Name And Address of Customer : MIET PUBLIC SCHOOL  
POCKET Q, PALLAVPURAM PHASE-2  
MEERUT-250110

Date of Sample Received : 10.10.2025

Analysis Start Date : 11.10.2025

Analysis End Date : 15.10.2025

Sample ID No : 1367

Sampling Done By : BY CUSTOMER

Sampling Description : DRINKING WATER

Sampling Location : FROM R.O.

Sampling Method : IS 3025 (Part-1)

Sample Quantity : 2.0+0.5 Ltr

Packing Condition : SEALED

Packed In : P.V.C. AND GLASS BOTTLE

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012)		Test Method
				Desirable	Permissible	
<b>PHYSICAL &amp; CHEMICAL PARAMETERS;</b>						
1	pH	...	7.15	6.5 - 8.5	No Relaxation	APHA 4500-H+
2	Turbidity	NTU	<1.0	1	5	APHA 2130-B
3	Total Dissolved Solids,(TDS)	mg/L	117.3	500	2000	APHA 2540-C
4	Conductivity	µs/cm	175.8	No Relaxation	No Relaxation	APHA 2510-B
5	Free Chlorine (Residual)	mg/L	<0.02	0.2	1	APHA 4500:(Cl)-B
6	Fluoride,(F)	mg/L	<0.01	1	1.5	APHA 4500:(F-)-D
7	Total Alkalinity,(CaCO <sub>3</sub> )	mg/L	37.7	200	600	APHA 2320-B
8	Total Hardness,(CaCO <sub>3</sub> )	mg/L	50.9	200	600	APHA 2340-C
9	Calcium,(Ca)	mg/L	9.4	75	200	APHA 3500:(Ca)-B
10	Chloride,(Cl)	mg/L	8.0	250	1000	APHA 4500:(Cl)-B
11	Magnesium,(Mg)	mg/L	6.5	30	100	APHA 3500:(Mg)-B
12	Nitrate,(NO <sub>3</sub> )	mg/L	<0.1	45	No Relaxation	APHA 4500:(NO <sub>3</sub> )-B
13	Sulphate,(SO <sub>4</sub> )	mg/L	9.6	200	400	APHA 4500:(SO <sub>4</sub> )-E
<b>HEAVY METALS:-</b>						
14	Iron,(Fe)	mg/L	<0.05	1.0	No Relaxation	APHA-3120B

\*\*\*\*\*End of Test Report\*\*\*\*\*

For MIET PUBLIC SCHOOL

CHECKED BY  
RAMIZA BANO

Format No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

For Enviro Tech Services Pvt. Ltd

For MIET PUBLIC SCHOOL

AUTHORIZED SIGNATORY

Note :-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. This sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.





# ENVIRO TECH SERVICES PVT. LTD.

An Analytical Laboratory



(AN ISO 45001:2018 Certified Laboratory)

Plot No. 1/32, S.S. of G.T. Road Industrial Area, Ghaziabad (U.P.) - 201001

E-mail : etslab2012@gmail.com | Website : www.etslab.in | Ph.: 9911516076, 8130255461

## TEST REPORT

TEST REPORT NO.: ETS/1367/10/2025

DATE OF REPORT: 15.10.2025

## WATER SAMPLE ANALYSIS REPORT

S. No.	Test Parameter	Unit	Result	Specification/Limit (As per IS:10500: 2012 )	Test Method
<b>MICROBIOLOGICAL PARAMETER;</b>					
15	Escherichia coli	Per 100mL	Absent	Shall Not Be Detectable	IS15185

\*\*\*\*\*End of Test Report\*\*\*\*\*

CHECKED BY  
JYOTI

No ETS/LAB/TR-09, Issue No. 05, Date 01.04.2019, Amd. No. 04 Date 01.04.2019

AUTHORIZED SIGNATORY

For MIET PUBLIC SCHOOL

  
Principal

For MIET PUBLIC SCHOOL

  
Manager

Note :-

1. Test reports without ETS LAB HOLOGRAM are not issued by our laboratory.
2. The results indicated only refer to the tested samples and listed applicable parameters.
3. No complaint will be entertained if received after 7 days of issue of test report.
4. Our liability is limited to invoice value only.
5. This sample shall be destroyed after 15 days & Biological / Perishable sample shall be destroyed immediately after issue of test report.
6. This test report shall not be used in any advertising media or as evidence in the court of Law without prior written permission of the laboratory.



National Accreditation Board for  
Testing and Calibration Laboratories

NABL

**CERTIFICATE OF ACCREDITATION**

**ENVIRO TECH SERVICES PRIVATE LIMITED**

has been assessed and accredited in accordance with the standard

**ISO/IEC 17025:2017**

**"General Requirements for the Competence of Testing &  
Calibration Laboratories"**

for its facilities at

PLOT NO. 1/32, SOUTH SIDE G T ROAD INDUSTRIAL AREA, GHAZIABAD, UTTAR PRADESH, INDIA

in the field of

**TESTING**

Certificate Number: TC-15390

Issue Date: 02/02/2026

Valid Until: 01/02/2030


This certificate remains valid for the Scope of Accreditation as specified in the annexure subject to continued satisfactory compliance to the above standard & the relevant requirements of NABL.  
(To see the scope of accreditation of this laboratory, you may also visit NABL website [www.nabl-india.org](http://www.nabl-india.org))

Name of Legal Entity: ENVIRO TECH SERVICES PRIVATE LIMITED

Signed for and on behalf of NABL



  
Anuja Anand  
Director

  
Dr. Ramanand N. Shukla  
Chief Executive Officer

For MIET PUBLIC SCHOOL

  
Principal

For MIET PUBLIC SCHOOL

  
Manager